

Approved : Takahiro Yoneda
Takahiro YonedaPrepared : Satoshi Kinoshita
Satoshi Kinoshita

No.	Test item	Conditions	Conditions of Acceptability	Result
1	Line conduction	(1) Rated input AC100V,230V (2) Rated load (3) Ambient temp. $25\pm 10^{\circ}\text{C}$	(1)Meets the undermentioned standard. VCCI classA	OK
2	Radiated emission	(1) Rated input AC100V,230V (2) Rated load (3) Ambient temp. $25\pm 10^{\circ}\text{C}$	(1)Meets the undermentioned standard. VCCI classA	OK
3	Harmonic current (EN61000-3-2)	(1) Rated input AC230V (2) Load 0 - Rated load (3) Ambient temp. $25\pm 10^{\circ}\text{C}$	(1)Meets the undermentioned standard. EN61000-3-2 classA	OK
4	Static electricity immunity test (EN61000-4-2)	(1) Rated input AC230V (2) Rated load (3) Ambient temp. $25\pm 10^{\circ}\text{C}$ (4) Contact discharge voltage 8[kV] (Level 4)	(1)No protection circuit failure. (2)No output voltage drop with control circuit failure. (3)No any other function failure	OK
5	Radiated, radio-frequency, electromagnetic field immunity test (EN61000-4-3)	(1) Rated input AC230V (2) Rated load (3) Ambient temp. $25\pm 10^{\circ}\text{C}$ (4)Testing field strength (Level 3) ① 10[V/m] (80MHZ to 1.0GHz) ② 3[V/m] (1.4GHZ to 2.0GHz) ③ 1[V/m] (2.0MHZ to 2.7GHz)	(1)No protection circuit failure. (2)No output voltage drop with control circuit failure. (3)No any other function failure	OK
6	Electrical fast transient/ burst immunity test (EN61000-4-4)	(1) Rated input AC230V (2) Rated load (3) Ambient temp. $25\pm 10^{\circ}\text{C}$ (4) Test peak voltage 4[kV] (Level 4)	(1)No protection circuit failure. (2)No output voltage drop with control circuit failure. (3)No any other function failure	OK
7	Surge immunity test (EN61000-4-5)	(1) Rated input AC100V (2) Rated load (3) Ambient temp. $25\pm 10^{\circ}\text{C}$ (4) Test voltage Line to line 2[kV] (Level 3) Line to earth 4[kV] (Level 4)	(1)The power supply is not stop (2)Circuit does not malfunction. (3)No abnormality of the insulation destruction etc. (4)Parts are no damaged.	OK
8	Immunity to conducted disturbances, induced by radio-frequency fields (EN61000-4-6)	(1) Rated input AC230V (2) Rated load (3) Ambient temp. $25\pm 10^{\circ}\text{C}$ (4) Voltage level (e.m.f.) 10[V] (Level 3)	(1)No protection circuit failure. (2)No output voltage drop with control circuit failure. (3)No any other function failure	OK
9	Power frequency magnetic field immunity test (EN61000-4-8)	(1) Rated input AC230V (2) Rated load (3) Ambient temp. $25\pm 10^{\circ}\text{C}$ (4) Magnetic field strength 30[A/m] (Level 4)	(1)No protection circuit failure. (2)No output voltage drop with control circuit failure. (3)No any other function failure	OK
10	Voltage dips, short interruptions and voltage variations immunity test (EN61000-4-11)	(1) Rated input AC230V •30% reduction at 10mS min. •60% reduction at 100mS min •95% reduction at 5S min. • $\pm 10\%$ variation at 15 minutes (2) Rated load (3) Ambient temp. $25\pm 10^{\circ}\text{C}$	(1)No protection circuit failure. (2)No output voltage drop with control circuit failure. (3)No any other function failure	OK