

TEST DATA OF TAC-60-□ □ □

Noise Filter

Oct. 31, 2011

Approved by : Toshio Watanabe Watanabe
Toshio Watanabe Design Manager

Prepared by : Yuichi Uozu Yuichi Uozu Design Engineer

COSEL CO.,LTD.



CONTENTS

1.Attenuation Characteristics	1
2.Leakage Current	3
3.Figure of Testing Circuitry	4



(Final Page 4)


coSEL

Model TAC-60-□□□

Item Attenuation Characteristics

Object

Temperature 25°C
Testing Circuitry Figure A

COSEL



Model	TAC-60-□□□	Temperature	25°C
Item	Leakage Current	Testing Circuitry	Figure B
Object	<hr/>		

1. Results

[mA]

Model	Standards	Input Volt.					Note
		200 [V]	250 [V]	400 [V]	480 [V]	500 [V]	
TAC-60-103	UL1283	0.62	0.78	1.3	1.5	1.6	
TAC-60-223	UL1283	1.4	1.8	2.8	3.3	3.5	
TAC-60-333	UL1283	2.1	2.7	4.2	5.1	5.3	

2. Condition

Leakage current value is concluded after measuring both phases of AC input and by choosing the larger one.

COSEL




Figure A - 1 Differential mode attenuation measurement




Figure A - 2 Common mode attenuation measurement




Figure B Leakage current measurement (UL1283)